



Product Service

CERTIFICATE

No. U6 040053 0003 Rev. 00

Holder of Certificate: Durlum GmbH

An der Wiese 5
79650 Schopfheim
GERMANY

Certification Mark:



Product:

**Recessed luminaires
LED recessed luminaires**

The product was voluntarily tested according to the listed standards. The product can be marked with the certification mark shown above. The certification mark must not be altered in any way. See also notes overleaf.

Test report no.:

028-713138321-000 Rev. 00

Date, 2018-11-08

(Thomas Kokorsch)

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT ◆ CERTIFICATE

A4 / 07-17



Product Service

CERTIFICATE

No. U6 040053 0003 Rev. 00

Model(s): 15-A17-858-50; 15-A17-858-55;
15-A17-858-56; 15-A17-858-57

Parameters:

Model	15-A17-858-50	15-A17-858-55	15-A17-858-56	15-A17-858-57
Rated voltage	230 V	230 V	230 V	230 V
Rated frequency	50Hz	50Hz	50Hz	50Hz
Rated power	19W	24W	29W	34W
Protection class	II	II	II	II
Degree of protection	IP 65	IP 65	IP 65	IP 65
IK Code	10	10	10	10

Tested according to: EN 60598-1:2015/A1:2018
EN 60598-2-2:2012

Production Facility(ies): 040053

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFIKAT ◆ CERTIFICATE ◆ CERTIFICATE